

## SECTION 341

### EXTRUDED ASPHALT CURB

#### 341.1 GENERAL

341.1.1 The work covered by this section consists of furnishing all plant, labor, equipment, materials, and in performing all operations in connection with the construction of asphalt curbs in accordance with these specifications.

#### 341.2 REFERENCES

#### 341.3 MATERIALS

341.3.1 The asphaltic concrete for asphaltic concrete curb construction shall be produced with 60-70 penetration asphalt or AC-20 viscosity grade asphalt and in accordance with an approved job mix formula.

#### 341.4 EQUIPMENT

341.4.1 All equipment, tools, and machines used in the performance of the work covered by this section of the specifications shall be subject to the approval of the ENGINEER and shall be maintained in a satisfactory working condition at all times.

#### 341.5 CONSTRUCTION METHODS

341.5.1 Asphalt curbs shall be machine laid. The machine shall be approved by the ENGINEER and shall be of a type in which the asphalt material is extruded or pushed out through a mold form under compaction pressure by a horizontal conveyor screw. A tack coat, as approved by the ENGINEER, shall be applied to the portion of the pavement to which the curb is to be affixed prior to extrusion.

#### 341.6 MEASUREMENT AND PAYMENT

341.6.1 Asphalt curb shall be measured by the linear foot. Measurement shall be made along the bottom edge of the street side of the curb. Asphalt curb shall be paid for at the contract unit price per linear foot bid, which price and payment shall be full compensation for furnishing all material, labor, equipment, and in performing all operations and incidentals necessary to complete the work, including placement of a tack coat on existing pavement beneath base of curb.